

Approval Number: 1607539
Test Report: MAT/LAB 578K. rev. 1



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

10th May 2017

METSAN ENDÜSTRİYEL YAPIŞTIRICILAR TİCARET A.Ş.
Tersane Caddesi Nafe Sokak Erdoğanlar İşMrk. No.1,
Kat.2 34420 Karaköy,
İstanbul,
Turkey

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS - SCREWED JOINTS - GENERAL.

5510

'EMS Force 5543'. Blue coloured pipe sealant. Apply as per manufacturer's instructions. Cure for 24 hours@22°C - 24°C. For use with water up to 85°C.

APPROVAL NUMBER: 1607539

APPROVAL HOLDER: METSAN ENDÜSTRİYEL YAPIŞTIRICILAR TİCARET A.Ş.

The Scheme reserves the right to review approval.

Approval 1607539 is valid between July 2016 and July 2021

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme