

Approval Number 2305511
Test Report: J-00458606



16th May 2023

Metsan Endüstriyel
Bati Cad. 1.Sok No.1,
34953 Aydinli - Birlik OSB,
Tuzla/ Istanbul, TR-34,
Turkey

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS - SCREWED JOINTS- GENERAL.

5510

'EMS Force 5543'. Blue coloured pipe sealant.
Apply as per manufacturer's instructions 'TLM.LB.07', version '0', issue date '07/03/2016'. Cure for 24 hours@23°C.

For use with water up to 85°C.

This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 2305511
APPROVAL HOLDER: METSAN ENDÜSTRIYEL

The Scheme reserves the right to review approval.
Approval 2305511 is valid between May 2023 and May 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager